

Product Discontinuation Notices

Programmable Controllers

Issue Date
June 2, 2014

No. 2014055CE

Discontinuation Notice of CQM1-PA216, AC Power Supply Units.

Product Discontinuation

AC Power Supply Units



Model CQM1-PA216



Recommended Replacement

AC Power Supply Units

Model CQM1-PA206

[Discontinuation date]

The end of March, 2015

[Caution on recommended replacement]

A part of characteristics of CQM1-PA206 is different from CQM1-PA216.
The CQM1-PA206 doesn't comply with EC Directives.

[Difference from discontinued product]

Recommended replacement Model	Body Color	Dimensions	Wire connection	Mounting Dimensions	Characteristics	Operation ratings	Operation methods
CQM1-PA206	**	**	**	**	*	**	**

** : Compatible

* : The change is a little/Almost compatible

-- : Not compatible

- : No corresponding specification

[Product Discontinuation and recommended replacement]

Product discontinuation	Recommended replacement
CQM1-PA216	CQM1-PA206
	In the case of necessity with CE marking, the following units are recommended for replacement. Switch mode power supply with CE marking (50W type) and CQM1-PD026 (DC24V)

[Characteristics]

Item	Product discontinuation Model CQM1-PA216	Recommendable replacement Model CQM1-PA206
Supply voltage	100V or 230V AC (selectable), 50/60 Hz	100 to 240V AC, 50/60 Hz
Allowable voltage range	85 to 132V AC or 170 to 264V AC	85 to 264V AC
Conformance to EC Directives	Applied	Not Applied

Item	Product discontinuation Model CQM1-PA216	Recommendable replacement Model CQM1-PD026
Supply voltage	100V or 230V AC (selectable), 50/60 Hz	24V
Allowable voltage range	85 to 132V AC or 170 to 264V AC	20 to 28V DC
Conformance to EC Directives	Applied	Applied

Specifications and prices in this product news are as of the issue date and are subject to change without notice.
Only main changes in specifications are described in this document. Please be sure to read the relevant catalogs, datasheets, product specifications, instructions, and manuals for precautions and necessary information when using products.